

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 10/06/2026

It is certified that an inspection team headed by Ashok kumar (Medical Officer)..

(Name of Officers with designation) from Public Health Department_PHED inspected

the S S Convent School & Khemaupur Chandeshwar Azamgarh U.P. (Name & Address of the

school) on 30.05.2026 (date of inspection) and on the basis of Water Test Report

(Attached) bearing no. C/VNS/MAY26/622 dated 30.05.2026 of **Regional Water**

Analysis Laboratory, (PHED Lab) certified that the **S S Convent School** (Name of

school) has safe drinking water facilities for the students and members of staff of the

institution. School is also maintains the hygienic sanitation condition in the school

building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **1 Year** from date of issue.

Signature with Seal:

Name

सामुदायिक स्वास्थ्य केन्द्र
सदरियाँ, आजमगढ़

Designation

.....

Name & Address of the Office/ Department:.....

To

The Manager,

S S Convent School,

Khemaupur, Chandeshwar, Azamgarh U.P

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.

Water Analysis Report



Regional Water Analysis laboratory
(An NABL Accredited Laboratory)
Ganga Pollution Control Unit Campus,
U.P. Jal Nigam (Rural),
Varanasi- 221005



Report No: C/VNS/MAY26/586

Date: 30/05/2026

No. of Pages:1

Customer Details

Office Name and Address **S S CONVENT SCHOOL, KHEMAUPUR, CHANDESHWAR AZAMGARH**
Ref Letter No. & Date **NA** Date: 30/05/2026

Basic Details of sample

District	Azamgarh	Block	Sathiaon
Gram Panchayat	Khemaupur	Village	Khemaupur
Habitation	NA	Location	KHEMAUPUR, CHANDESHWAR, AZAMGARH
Water Source	RO Water	Sample code	VNS/MAY26/586
Quantity of sample	1000 ml (Normal)	Sampling Date	29/05/2026
Sample Received Date	29/05/2026	S. collected by	Mr P.N. Mishra
Sampling Method Used	NA	S. Depositor	Mr P.N. Mishra
Analysis Start Date	29/05/2026	Analysis Completion Date	30/05/2026

S.No.	Analysed Parameters	Observed value	Specification as per IS 10500		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.04	6.5-8.5	6.5-8.5	Method
2	Colour(Hazen units)	Na	5	15	(Platinum Cobalt Visual Comparison):2017
3	Turbidity (NTU)	BDL(0.48)	1	5	Method
4	Total dissolved Solids, mh/l	70.01	500	2000	IS 3025(Part 16):1984, Gravimetric method)
5	Chloride (as Cl) mg/l	7.33	250	1000	Method
6	Total Alkalinity, (as CaCo3)mg/l	34.67	200	600	Indicator method
7	Total hardness (as CaCo3) mh/l	BDL(0.00)	200	600	IS 3025(Part 21):2009 EDTA method
8	Calcium(as Ca) mg/l	BDL(0.00)	75	200	Method
9	Magnesium(as Mg),mg/l	BDL(0.00)	30	100	IS 3025 (Part 46): 1994 (Volumetric method)
10	Sulphate(as SO4),mg/l	8.84	200	400	(Turbidimetric Method):2017
11	Nitrate (as NO3), mg/l	BDL(0.00)	45	No relaxation	(UV Screening Method):2017
12	Fluoride (as F), mg/l	Na	1.0	1.5	(Selective Electrode Method):2017
13	Iron (as Fe), mg/l	BDL(0.01)	1.0	No relaxation	(Phenanthroline Method): 2017
14	Total Arsenic (as As), mg/l	Na	0.01	No relaxation	(Diethyldithiocarbamat Method)2017

All these parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

All These parameters are under NABL Scope, BDI Below Detection Limit, NA Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis laboratory.

2. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.

3. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

4. Parameters above Permissible Limit are written in bold.

5. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.

6. Sample is not Collected by Lab.

ABHAY KUMAR PANDEY
(Report Prepared by)

